



Main

Range of product	RED
Range	Acti 9
Product or component type	Residual current circuit breaker (RCCB)
Device short name	RED
Protection type	Recloser
Poles description	2P
Neutral position	Left
[In] rated current	63 A
Earthing system	TN-S TT
Network type	AC
Earth-leakage sensitivity	30 mA

Complementary

Device location in system	Outgoer
Network frequency	50 Hz
[Ue] rated operational voltage	230 V AC 50 Hz phase to neutral
Reset	Fault reset earth leakage
Test function	Manual at 100 V
Earth-leakage protection time delay	Instantaneous
Earth-leakage protection class	Type A
Leakage resistance	120 kOhm
[Im] rated making and breaking capacity	Idm 630 A 230 V
Rated conditional short-circuit current	C120 : Inc 6 kA 63 A C60 : Inc 6 kA 63 A GL63 : Inc 6 kA 63 A gL NG125 : Inc 6 kA 63 A
[Ui] rated insulation voltage	500 V
[Uimp] rated impulse withstand voltage	4 kV
Control type	Toggle Sliding cover for recloser
Local signalling	Residual current device : ON/OFF indication

Recloser : ON/OFF indication
1 red LED

Type of setting	Restart cycle Max nb of consecutive restart Insulation fault presence monitoring Recloser Nb of restart operations Restart in event of transient insulation fault Min interval between 2 closings Stopping restart cycle if insulation fault present
Mounting mode	Fixed
Mounting support	35 mm symmetrical DIN rail
9 mm pitches	8
Height	115 mm
Width	71 mm
Depth	79.5 mm
Mechanical durability	1000 cycles open-close
Connections - terminals	Guard tunnel terminal 25 mm ² flexible Guard tunnel terminal 35 mm ² rigid
Auxiliary connection terminal	Tunnel type terminal flexible 2.5 mm ² Tunnel type terminal rigid 2.5 mm ²
Wire stripping length	12 mm
Tightening torque	2 N.m
Compatibility code	RED

Environment

Standards	IEC 61008 EN 61008
IP degree of protection	IP20
Electromagnetic compatibility	8/20 μ s wave immunity 250 A
Tropicalisation	2
Relative humidity	95 % (55 °C)
Ambient air temperature for operation	-5...40 °C
Ambient air temperature for storage	-20...60 °C

Contractual warranty

Warranty period	18 months
-----------------	-----------