



Main

Range	Masterpact
Range of product	Masterpact NT
Product name	Masterpact NT
Product or component type	Basic frame
Device short name	Masterpact NT02
Circuit breaker name	Masterpact NT02
Poles description	3P
Network type	AC
Breaking capacity code	H1

Complementary

Network frequency	50/60 Hz
Control type	Push-button
Mounting mode	Drawout
[In] rated current	250 A (40 °C)
[Ui] rated insulation voltage	1000 V AC 50/60 Hz conforming to IEC 60947-2
[Uimp] rated impulse withstand voltage	12 kV conforming to IEC 60947-2
[Ue] rated operational voltage	690/1000 V AC 50/60 Hz conforming to IEC 60947-2
Circuit breaker CT rating	250 A
Breaking capacity	42 kA Icu at 220...240 V AC 50/60 Hz conforming to IEC 60947-2 42 kA Icu at 380...415 V AC 50/60 Hz conforming to IEC 60947-2
Protection type	Without protection
Mechanical durability	12500 cycles without maintenance conforming to IEC 60947-2
Electrical durability	AC-23A : 3000 cycles 690 V AC 50/60 Hz without maintenance conforming to IEC 60947-2 AC-23A : 6000 cycles 440 V AC 50/60 Hz without maintenance conforming to IEC 60947-2 AC-3 : 6000 cycles 440 V AC 50/60 Hz without maintenance conforming to IEC 60947-2 3000 cycles 690 V AC 50/60 Hz without maintenance conforming to IEC 60947-2 6000 cycles 440 V AC 50/60 Hz without maintenance conforming to IEC 60947-2
Connection pitch	70 mm
[Icw] rated short-time withstand current	24 kA (3 s) conforming to IEC 60947-2 42 kA (0.5 s) conforming to IEC 60947-2 42 kA (1 s) conforming to IEC 60947-2
Height	322 mm

Disclaimer: This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications

Width	288 mm
Depth	276.5 mm
Compatibility code	NT02

Environment

Standards	IEC 60947-2
Product certifications	ASEFA LCIE
Pollution degree	3 conforming to IEC 60664-1
Ambient air temperature for operation	-25...70 °C
Ambient air temperature for storage	-40...85 °C

Contractual warranty

Warranty period	18 months
-----------------	-----------