



Main

Range	Masterpact
Range of product	Masterpact NT Masterpact NW DC Masterpact NW
Device short name	MN
Product or component type	Voltage release
Device application	Control
Range compatibility	Masterpact NW Masterpact NT
Voltage release type	Undervoltage release
[Uc] control circuit voltage	48 V AC 48...60 V DC

Complementary

Threshold tripping voltage	0.35...0.7 U_n - during opening time 0.85 U_n - during closing time
Supply holding power	4.5 VA
Mounting mode	Fixed
Response time	40 ms Masterpact NT 90 ms Masterpact NW

Contractual warranty

Warranty period	18 months
-----------------	-----------

47381