



### Main

Range	Masterpact
Range of product	Masterpact NW DC Masterpact NW UL 489 Masterpact NW
Device short name	MN
Product or component type	Voltage release
Device application	Control
Range compatibility	Masterpact NW
Voltage release type	Undervoltage release
[Uc] control circuit voltage	48 V AC 48...60 V DC

### Complementary

Threshold tripping voltage	0.35...0.7 $U_n$ - during opening time 0.85 $U_n$ - during closing time
Supply holding power	4.5 VA
Mounting mode	Drawout
Response time	90 ms Masterpact NW

### Contractual warranty

Warranty period	18 months
-----------------	-----------

48502