



Main

Relay application	Busbars
Range of product	Sepam series 20
Device short name	B22
Control and monitoring type	Circuit breaker/contactor control ANSI code: 94/69 (option) Latching/Acknowledgement ANSI code: 86 Annunciation ANSI code: 30
Metering type	Voltage U21, U32, U13, V1, V2, V3, residual voltage V0 Positive sequence voltage Vd/rotation direction Frequency
Network and machine diagnosis type	Disturbance recording
Switchgear diagnosis type	Trip circuit supervision (option)

Complementary

Type of measurement	Frequency Voltage
Protection type	Remanent undervoltage ANSI code: 27R Overfrequency ANSI code: 81H Underfrequency ANSI code: 81L Rate of change of frequency ANSI code: 81R Neutral voltage displacement ANSI code: 59N Phase-to-neutral undervoltage ANSI code: 27S Phase-to-phase overvoltage ANSI code: 59 Phase-to-phase undervoltage ANSI code: 27 Positive sequence undervoltage ANSI code: 27D/47
Communication port protocol	Measurement readout (option) : Modbus Remote control orders (option) : Modbus Remote indication and time tagging of events (option) : Modbus Remote protection setting (option) : Modbus Transfer of disturbance recording data (option) : Modbus
Input output max capacity	10 inputs + 8 outputs
Communication compatibility	DNP3 IEC 60870-5-103 Modbus RTU IEC 61850
User machine interface type	Remote Advanced Without

Disclaimer: This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications

Offer Sustainability

Product environmental profile

Available

 Product environmental