

\*\*\*Spare part\*\*\* SIPLUS S7-1200 SM 1231 TC with conformal coating based on 6ES7231-5QD30-0XB0 . Analog input, 4 AI thermocouples



Figure similar

General information	
Product type designation	SM 1231, AI 4x16 bit TC
Supply voltage	
Rated value (DC)	
• 24 V DC	Yes
Input current	
Current consumption, typ.	40 mA
from backplane bus 5 V DC, typ.	80 mA
Power loss	
Power loss, typ.	1.5 W
Analog inputs	
Number of analog inputs	4; Thermocouples
permissible input voltage for current input (destruction limit), max.	± 35 V
permissible input voltage for voltage input (destruction limit), max.	+35 V

Technical unit for temperature measurement adjustable	Degrees Celsius/degrees Fahrenheit
<b>Input ranges</b>	
• Thermocouple	Yes; J, K, T, E, R, S, N, C, TXK/XK(L); voltage range: $\pm 80$ mV
• Resistance thermometer	No
• Resistance	Yes
<b>Input ranges (rated values), voltages</b>	
• -80 mV to +80 mV	Yes
• Input resistance (-80 mV to +80 mV)	$\geq 1$ MOhm
<b>Input ranges (rated values), thermocouples</b>	
• Type C	Yes
• Type E	Yes
• Type J	Yes
• Type K	Yes
• Type N	Yes
• Type R	Yes
• Type S	Yes
• Type T	Yes
• Type TXK/TXK(L) to GOST	Yes
<b>Thermocouple (TC)</b>	
Temperature compensation	
— parameterizable	No
<b>Analog value generation for the inputs</b>	
Measurement principle	integrating
<b>Integration and conversion time/resolution per channel</b>	
• Resolution with overrange (bit including sign), max.	15 bit; + sign
• Integration time, parameterizable	No
• Interference voltage suppression for interference frequency $f_1$ in Hz	85 dB at 50 / 60 / 400 Hz
<b>Smoothing of measured values</b>	
• parameterizable	Yes
<b>Errors/accuracies</b>	
Temperature error (relative to input range), (+/-)	25 °C $\pm 0.1\%$ , to 55 °C $\pm 0.2\%$ total measurement range
Repeat accuracy in steady state at 25 °C (relative to output range), (+/-)	0.5 %
<b>Interference voltage suppression for <math>f = n \times (f_1 \pm 1 \%)</math>, <math>f_1</math> = interference frequency</b>	
• Common mode interference, min.	120 dB
<b>Interrupts/diagnostics/status information</b>	
Alarms	Yes
Diagnostic functions	Yes; Can be read out

Alarms	
• Diagnostic alarm	Yes
Diagnostic messages	
• Monitoring the supply voltage	Yes
• Wire-break	Yes
Diagnostics indication LED	
• for status of the inputs	Yes
• for maintenance	Yes
Degree and class of protection	
Degree of protection acc. to EN 60529	
• IP20	Yes
Standards, approvals, certificates	
CE mark	Yes
FM approval	Yes
RCM (formerly C-TICK)	Yes
Ambient conditions	
Free fall	
• Fall height, max.	0.3 m; five times, in product package
Ambient temperature during operation	
• min.	0 °C; = Tmin
• max.	55 °C; = Tmax
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
• Ambient air temperature-barometric pressure-altitude	Tmin ... Tmax at 1 080 hPa ... 795 hPa (-1 000 m ... +2 000 m) // Tmin ... (Tmax - 10 K) at 795 hPa ... 658 hPa (+2 000 m ... +3 500 m) // Tmin ... (Tmax - 20 K) at 658 hPa ... 540 hPa (+3 500 m ... +5 000 m)
Relative humidity	
• With condensation, tested in accordance with IEC 60068-2-38, max.	100 %; RH incl. condensation/frost permitted (no commissioning in bedewed state)
Resistance	
Use in stationary industrial systems	
— to biologically active substances according to EN 60721-3-3	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
— to chemically active substances according to EN 60721-3-3	Yes; Class 3C4 (RH < 75%) incl. salt spray according to EN 60068-2-52 (degree of severity 3). The supplied connector covers must remain on the unused interfaces during operation!
— to mechanically active substances according to EN 60721-3-3	Yes; Class 3S4 incl. sand, dust. The supplied connector covers must remain on the unused interfaces during operation!
Connection method	

required front connector	Yes
--------------------------	-----

### Mechanics/material

Enclosure material (front)	
• Plastic	Yes

### Dimensions

Width	45 mm
Height	100 mm
Depth	75 mm

### Weights

Weight, approx.	180 g
-----------------	-------

<b>last modified:</b>	05/18/2018
-----------------------	------------